

- Are all exits marked with an exit sign that is illuminated by a reliable light source?
- Do the exit signs have lettering that is at least 5 inches high and the stroke of the lettering at least ½ inches wide?
- Are the directions to exits, when not immediately apparent, marked with visible signs.
- Are all exits (hallways and doors) maintained free of obstructions at all times? Check both sides of exit doors.
- Are there a sufficient number of exits to permit prompt escape in case of emergency?
- Do all exit doors open easily and in the direction of travel without the use of a key or any special knowledge or effort?
- Are all exit doors unlocked during hours employees are in the building?
- Is the number of exits from each floor or a building and the number of exits from the building itself appropriate for the building occupancy? Overhead, revolving and sliding doors are not considered exits.
- Are at least two means of egress provided from elevated platforms, pits or rooms where the absence of a second exit would increase the risk of injury from hot, poisonous, corrosive, suffocating, flammable or explosive materials?
- Are accommodations made to provide egress during construction and repair operations that impact existing exits?
- Where exiting will be through frameless glass doors, glass exit doors or storm doors, are the doors fully tempered and meet the safety requirements for human impact?
- Where exit doors open directly onto the street, alley or other area where vehicles may be operated, are adequate barriers and warnings provided to prevent employees from stepping into the path of traffic?
- Are doors on cold storage rooms provided with an inside release mechanism which will release the latch?