

- Are grinders, saws and similar equipment provided and used with appropriate guards at all times?
- Are power tools used with the correct shield, guard, or attachment recommended by the manufacturer?
- Are portable circular saws equipped with guards above and below the base shoe?
- Are rotating or moving parts of equipment guarded to prevent physical contact?
- Are all cord-connected, electrically operated tools and equipment effectively grounded or approved double insulated?
- Are effective guards in place over belts, pulleys, chains, sprockets, on equipment such as concrete mixers and air compressors?
- Are portable fans provided with full guards or screens with openings of ½ inch or less?
- Are ground fault circuit interrupters (GFCI) provided on all temporary electrical 15 and 20 ampere circuits used during periods of construction?
- Are pneumatic and hydraulic hoses on power operated tools checked regularly for deterioration or damage?
- Are radial arm saws so arranged that the cutting head will return to the back of the table when released?